

## RFP Requirements of fire Systems

CO<sub>2</sub> Fire Fighting System. The installed system should meet all requirements as specified in SOTR DME/SOTR/EG-4707/04/CO<sub>2</sub>/NBCD.

Foam Making System. A fixed foam system will be provided in all machinery spaces. Foam concentrate is to be supplied from a tank having capacity to allow a minimum of 10 min continuous spraying.